

Addendum No. 2

Entwistle Pool and Community Hub Demolition Request for Quotations No. Q190102CM

Amendments

1. Respondents shall note the following change to Section 1.2 RFQ Timetable:

Was:

Submission Deadline	February 11, 2019 at 14:00:00 hrs local time
---------------------	--

Is Now:

Submission Deadline	February 13, 2019 at 14:00:00 hrs local time
---------------------	--

Clarification

2. In reference to Question #30 in Addendum No. 1:

The Contractor should cut the pile of 3 metres below grade, using existing grade level. Any additional pile length can remain in the ground.

******Acknowledgement of this Addendum is required in the submission******