

**Underground Gas Secondary Lines** In Areas Where Line Will Not Be Driven Over **Minimum Depth** 15 " of **Ground Surface** Cover **Back Fill** 15" **Gas Line Undisturbed Undisturbed** Soil Soil In Areas Where Line Will Be Driven Over **Minimum Depth** 24" of **Ground Surface** Cover **Back Fill** 24" **Gas Line Undisturbed Undisturbed** Soil Soil